

1 **ADDENDUM NO. 1 (Rev 1/2023)**

2 **ISSUE DATE: February 9, 2026**

3

4 **RE: ROOF REPLACEMENT**
5 **BLACK RIVER CORRECTIONAL CENTER**
6 **DEPARTMENT OF CORRECTIONS**
7 **BLACK RIVER FALLS, WISCONSIN**

8

9 Division Project No. **24J1H**

10

11 **BID SUBMISSION DUE by 1:00PM, BID OPENING for GPC BIDDERS: 2:00 PM: February 19, 2026.**

12

13

14 **FROM: Lien and Peterson Architects**
15 **4675 Royal Drive**
16 **Eau Claire, Wisconsin 54701**

17

18 **TO: Prospective Bidders**

19

20 This addendum forms a part of the Contract Documents and modifies the original Contract Documents dated
21 **January 6, 2026** as noted below. Acknowledge receipt of this Addendum by inserting the number and issue date
22 of this addendum in the blank space provided on the Bid Form. Failure to do so may subject the Bidder to
23 disqualification.

24

25 This Addendum consists of **two (2) pages** and the attached documents:

26

27

- **None**

28

29

- 30 **CHANGES TO BIDDING REQUIREMENTS:**
1. Instructions to Bidders, page B-10, item 21 – Commencement and Completion, line 37; insert the
31 following:
32 The Facility has not been able to obtain bird-control netting, and nesting swallows will be present under
33 the eaves and overhangs during a portion of the proposed construction schedule. Wildlife regulations
34 will require coordination.

35

36 **CHANGES TO CONDITIONS OF THE CONTRACT:**

37

38

39

2. None.

40

41

- 42 **CHANGES TO SPECIFICATIONS (DIVISIONS 2 THRU 34):**
3. Section 07 61 31 - Standing Seam Sheet Metal Roofing, page 07 61 31-11, line 12: revise reference to
43 2" high rolled seam to 1 1/2" high rolled seam.
 4. Section 07 61 31 - Standing Seam Sheet Metal Roofing, page 07 61 31-11, line 23: revise reference to
44 2" high rolled seam to 1 1/2" high rolled seam.
 - 45 4. Section 07 61 31 - Standing Seam Sheet Metal Roofing, page 07 61 31-16, line 13: revise reference to
46 2" high rolled seam to 1 1/2" high rolled seam.
 - 47 5. Section 07 61 31 - Standing Seam Sheet Metal Roofing, page 07 61 31-16, line 13: revise reference to
48 2" high rolled seam to 1 1/2" high rolled seam.
 - 49

1
2
3
4
5
6
7
8
9
10
11
12
13

CHANGES TO DRAWINGS:

- 6. Sheet A501 Details; revise all references to 2” high rolled seam are to be 1 1/2” high rolled seam.
- 7. Sheet A502 Details; revise all references to 2” high rolled seam are to be 1 1/2”high rolled seam.

END OF ADDENDUM

Lien and Peterson Architects
4675 Royal Drive
Eau Claire, Wisconsin 54701

Division of Facilities Development
Department of Administration
Madison, Wisconsin 53707-7866